3P SAFETY
Driving the industry to a safer tomorrow.
309 N William St, Goldsboro, NC 27530 • (252) 274-0583 • contact@3psafety.net

OVERHEAD & GANTRY CRANE

Monthly Documented Inspection Checklist — OSHA 29 CFR 1910.179 · ASME B30.2 · NCCCO-CERTIFIED

For overhead, bridge, and gantry cranes — top-running, under-running, single- and double-girder.

Crane / Unit ID:	Make / Model:	Date:	Inspector:

Monthly Documented Inspection Checklist

Competent person — the monthly portion of the frequent inspection under OSHA 1910.179(j)(2). Document for hoists used to lift people or near rated load.

ROPE, CHAIN & HOOK

- ☐ Wire rope or load chain along its full length
- ☐ Hook measured for throat opening and wear
- ☐ Load block, equalizer, and reeving

BRAKES & DRIVE

- ☐ Hoist brake holds and releases
- ☐ Bridge and trolley brakes and travel
- ☐ Gearing and couplings — function and noise

FUNCTION & DEVICES

- ☐ Limit switches and interlocks
- ☐ Controls and contactors
- ☐ Festoon, conductor bar, and power feed — visible condition

RECORD

- ☐ Date, crane ID, and inspector name
- ☐ Findings and any item pulled from service
- ☐ Signature on file

Deficiencies found / corrective action

Inspector signature

Date

Disclaimer. This checklist is a free educational field aid, not professional or legal advice. It does not replace the documented inspection by a qualified person that OSHA and ASME require, and it does not cover every condition on every machine — always follow the manufacturer's manual and the current OSHA / ASME standards. Use at your own risk; 3P Safety Inspections assumes no liability for its use. Take any crane with a safety defect out of service until a qualified person clears it.

Need a documented, qualified-person inspection? 3P Safety Inspections is an independent, third-party firm — we do not sell or rent cranes. NCCCO-certified inspectors · all 50 states · 24–72 hr scheduling · photo-documented reports. **(252) 274-0583 · 3psafetyinspections.com**